

Midwest Engineering McCook Lake House Designation 7-2-2024

Street	House #	Structural Check	House Safe to Retrieve	House Total Loss	Building Inspector Notes	Midwest Engineering Notes	
Penrose Drive	3	x	NO		Foundation and Access Issues	SW corner foundation undermined.	
	4	x	NO	YES	Foundation Collapse and Access Issues	-	
	5	x	Yes		Ok	Basement walls moved inward	
	6	x	NO		Garage Collapse	Garage collapsed.	
	7	x	Yes		Ok	-	
	8	x	NO		Foundation Collapse	No safe access and north non-load bearing wall undermined.	
	9	x	Yes		Ok	-	
	10	x	NO	YES	Foundation collapse	West load bearing foundation missing, tree impact.	
	11	x	Yes		Ok	-	
	12	x	Yes		Ok	-	
	13	x	Yes		Ok	-	
	14	x	Yes		Ok	-	
	15	x	Yes		Ok	-	
	16	x	Yes		Ok	-	
	17	x	Yes		Ok	-	
	18	x	Yes		Ok	-	
	19	x	Yes		Ok	-	
	20	x	Yes		Ok	-	
	22	x	Yes		Ok	-	
	Northshore Drive	19	x	Yes		Ok	-
		21	x	NO	YES	Collapsed	-
		23	x	NO	YES	Collapsed	-
24		x	Yes		Ok	-	
25		x	Yes		Okay	Retaining wall damage.	
27		x	Yes		NW Corner eroded. Caution Needed	NW & SE Garage foundations undermined.	
31		x	NO	YES	Collapsed	-	
33		x	NO	YES	Total Collapse	-	
35		x	Yes		Ok	East foundation partially undermined.	
36		x	Yes		Ok	-	
37		x	Yes		Ok	South side framing wall blown out.	
39		x	NO	YES	Foundation Lost	Garage and north side foundation undermined/missing.	
41		x	NO		Foundation Undermined NW Corner	NW Corner undermined.	
42		x	NO	YES	Partial Collapse, no access	-	
44		x	NO	YES	Foundation lost, No access	-	
45	x	NO	YES	Total Collapse	-		
47	x	NO	YES	Collapsed	-		
49	x	NO	YES	Foundation gone back wall	Garage unsafe to retrieve, backwall blown out by water.		
51	x	NO	YES	Collapsed, no access	Garage unsafe to retrieve.		
53	x	NO	YES	Total collapse	-		
55	x	NO	YES	Total Collapse	-		

	57	x	NO	YES	Foundation Lost	House/Garage both unsafe to retrieve
	59	x	NO	YES	Foundation unstable	House/Garage both unsafe to retrieve
	60	x	Yes		Access Issues, garage gone	Garage missing
	61	x	Yes		Foundation Undermined Lake Side	Deck unsafe lakeside, SW corner foundation undermined
	62	x	Yes		Ok	-
	63	x	NO	YES	Collapse	House/Garage both unsafe to retrieve
	65	x	NO		Basement and Foundation Partial Collapse	House/Garage both unsafe to retrieve, Garage is a Total Loss
	66	x	Yes		Ok	-
	67	x	NO	YES	Basement and Foundation Partial Collapse	House/Garage both unsafe to retrieve
	68	x	Yes		Ok	-
	71	x	NO	YES	Foundation Partial Collapse	House/Garage both unsafe to retrieve
	73	x	Yes		Ok	House may have previous basement damage
	75	x	Yes		Ok	-
	77	x	Yes		Basement and Foundation	-
	79	x	Yes		Foundation Undermined	House safe, garage foundation undermined and not safe
	81	x	Yes		Basement and Foundation Undermined	House east and west footing undermined.
	83	x	NO	YES	Basement and Foundation Undermined	Garage unsafe tor retrieve.
	85	x	NO	YES	Total Collapse	House unsafe, garage safe t o retrieve
	87	x	NO	YES	Basement and Foundation	House unsafe, garage safe to retrieve
	89	x	NO	YES	Foundation Undermined	Garage unsafe tor retrieve.
	91	x	NO	YES	Basement and Foundation	House unsafe, garage south wall undermined
	93	x	NO	YES	Basement and Foundation	House unsafe, detached garage safe to retrieve
	95	x	NO		Footing and Foundation Undermined West Side	East foundation partially undermined.
	97	x	Yes		Ok	-
	99	x	NO		Undermined Foundation	Footing undermined
	101	x	Yes		Basement and Foundation	-
	103	x	Yes		Ok	-
	105	x	Yes		Ok	-
	107	x	Yes		Ok	-